

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1101/161 of 2026 Dated: 31.08.2026

It is certified that an inspection team headed by P.W.D. Vavunari

(Name of Officers with designation) from Sumanth Singh Ramesh PHED

inspected the Microtek International School

(Name & Address of the school) on 29.8.2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 1101 dated 31.08.2026

of P.W.D. Vavunari (PHED Lab) certified that the

Microtek International School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 30.08.2027

Signature with Seal: सहायक अभियन्ता

Name : प्रान्तीय खण्ड, लोक निर्माण

Designation : बयानगरी

Name & Address of the Office / Department :

To Microtek International School
Vavunari

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Regional Water Analysis Laboratory, U.P. Jal Nigam, BHU-STP, Bhagwanpur, Varanasi – 221 005 (U.P.)
(Physical, Chemical and Microbiological Analysis Report of Water Samples)

1. Water Sample(s) received from : Principal, Microtek International School, Barai Baragaon, Varanasi 2. Analysis Report No. : 105
3. Date of obtaining Sample(s) & Letter No.: 27.08.2026 4. Report Dispatch No.: 63/कैम्प क्षेत्र.वा./रिपोर्ट, दिनांक-27.08.2026

Specification of Drinking Water as per IS 10500:2012 (Second Provision)		Permissible Limits		5	15	1.0	0.01	Unobjectionable/Objectionable	No Relaxation 6.5-8.5	2000	1000	400	1.5	45	0.1	200	100	1.0	600	600	Remark(s)			
		Acceptance Limits																						
Parameters (Unit) 																								
Details of Water Samples(s)																								
Sample No.	Source	Village Code No.	Name of Place/ Location	Block	District																			
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25
211	Sub-mersible	-	School Campus	BG	VNS	0.23	7.5	-	-	Unob	8.19	310	18	1.43	0.0	16	0.00	22.2	47	0.51	200	284	-	B

Special Remark if any: Satisfactory for oral consumption under measured condition.

Note:

- Sample(s) with any parameter value above acceptable limit will only be used for oral consumption if no other source is available.
- Parameters above the Permissible Limit of IS 10500:2012 (Second Revision) are written in bold with black shade.
- This certificate refers only to the particular sample(s) submitted for testing.
- Acidified samples for testing of Iron and Arsenic-wast were not received/received.
- this certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from the Head of Laboratory.
- The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.


 Signed by
 (Assistant Research Officer)
 UP Zonal Zone
 U.P. Jal Nigam, Varanasi